

Monitoring Violations Annual Notice Tier 3

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Cookeville Boat Dock Road Utility District

Our water system violated drinking water monitoring requirements over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

**We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the month of July, 2016 we failed to monitor for total coliform bacteria during regular time intervals. **

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant we did not properly test for during the last year, how often we are supposed to sample, how many samples we are supposed to take, how many samples we took, date samples should have been taken.

Contaminant	Required sampling frequency	Number of samples taken	Number of samples that should have been taken
Total Coliform Bacteria	8 per month at regular time intervals	8 all on the same day of July	8 evenly taken throughout July

What is being done?

During the month of July, 2016, we collected all total coliform bacteria samples on the same day. We are currently conducting the required total coliform bacteria samples during regular time intervals of each month and will continue to follow our bacteriological sampling plan now and into the future.

For further information please contact Robin Hawkins at 931-432-4459.

**Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail. **

This notice is being sent to you by Cookeville Boat Dock Road Utility District. Our State Water System ID# 0000134.

Date distributed: 04/10/2017